



Schemat podłączenia modułów oświetlenia awaryjnego typu:
Connection schema of emergency lighting kits :

| | |
|---------|---|
| TQ (ie) | ✓ |
| TQ AT | ✓ |

Legenda:

⑧ - miejsce rozłączenia obwodu w oprawie, gdzie "8" oznacza numer zacisku modułu oświetlenia awaryjnego do którego należy podłączyć dany przewód.

Uwaga!

Powyższy schemat połączeń może być niewłaściwy dla niektórych typów stateczników elektronicznych.

Przy wykonywaniu podłączenia modułu oświetlenia awaryjnego należy przestrzegać zaleceń producenta EVG dotyczących długości przewodów przyłączeniowych.

Wszystkie przewody przyłączeniowe powinny być jak najkrótsze.

Przed przystąpieniem do prac zapoznaj się z instrukcją użytkowania modułu oświetlenia awaryjnego TQ.

Prosimy o dokładne przetestowanie układu po zamontowaniu w oprawie. W razie pytań prosimy o kontakt z działem technicznym.

Legend:

⑧ - place of lead disconnection in fitting, where "8" mean number of emergency lighting kit's clip to which lead should be connected.

Attention!

The above connection scheme might be incompatible for some types of electronic ballasts.

During connection of emergency lighting kit, EVG manufacturer's recommendation according to length of lead should be obey.

All connection leads should be as short as possible.

Please read the manual of TQ emergency lighting kit carefully before use.

Please test carefully your circuit after instalation. In case of any questions, please contact to the technical department.

| | |
|------------|---------|
| NR. Schem. | 024 |
| Wersja | 01/2011 |